


## Water Quality Analysis Report

Location: KV School No.3

Date: 01-09-2020

	Result	Desired Limit
1. pH	6.81	( 6.5 to 8.5)
2. Electrical Conductivity	171 $\mu$ mhos/cm	(750)
3. Total Dissolved Salts	80 mg/l	(<500)
4. Carbonate	NIL	
5. Bicarbonate	108 mg/l	
6. Total Alkalinity	108 mg/l	(<200)
7. Chloride	68 mg/l	(<250)
8. Total Hardness	60 mg/l	(<200)
9. Calcium	44 mg/l	(<75)
10. Magnesium	16 mg/l	(<30)
11. Acidity	8 mg/l	
12. Fluoride	0.285 mg/l	(<1)
13. Nitrate	0.3 mg/l	(<45)

  
**Dr. N. Varadarajan, PRA**  
National Institute of Hydrology  
(Govt. of India, Ministry of Jal Shakti)  
Main Road, Vivekvaraya Nagar,  
BELAGAVI-590019.

  
11/9/2020